

# Popcorn Ash at Bowen Power Plant: Experience and Removal Strategies

---

**NETL / DOE**

**2003 Conference on Selective Catalytic Reduction and  
Non-Catalytic Reduction for NO<sub>x</sub> Control  
October 29-30, 2003**

**Marie Craig, Southern Company  
Chris Ayers, Enerfab Inc.  
Larry Bohannon, Georgia Power  
Dr. Klaus Weigl, Envirgy GmbH**



## **PRESENTATION OUTLINE**


- Plant Bowen Plugging History
- Investigation Behind Plugging
- Laboratory Catalyst Rejuvenation Tests and Results
- Technological Solutions
- On-site Catalyst Rejuvenation Process
- Catalyst Rejuvenation Results and Conclusions

## **SOUTHERN COMPANY GEORGIA POWER PLANT BOWEN FACTS**

- Four (4) CE (Alstom) T-fired units
- 3200 MW Total Operation
- Central Appalachian Coal (KY)
- Units 1 and 2 each 750 MW equipped with SCR systems in Spring 2001
- SCR are 3+1 layer reactor design
- Cormetech 7.1mm pitch honeycomb catalyst



## PLUGGING HISTORY



**UNIT 1** – Placed in service May 2001.  $\Delta P$  increased from 0.7 to 4 inches H<sub>2</sub>O within 69 days (~1650 hours)

**UNIT 2** – Placed in service July 2001. An increase in  $\Delta P$  caused the plant to take Unit 2 SCR offline after ~1464 hours.

## PLUGGING HISTORY

***After the SCR was brought offline:***

### **Observations:**

- No significant ash buildup on the screens.
- Catalyst channels plugged with fly ash and large particle ash
- Gradient of pluggage across the reactor

### **Actions:**

- Screens were removed
- “In-situ” cleaning performed
- Units operated remainder of ozone season.



TOP CATALYST LAYER

## PLUGGING HISTORY

### **After the 2001 Ozone Season:**


- Layers 1 and 2 of Unit 1 were replaced with new catalysts
- Economizer outlet baffle plate installed
- Units 1 & 2 operated entire 2002 Ozone Season

### **Post 2002 Ozone Season:**

- Amount of pluggage decreased, but was still significant
- Southern Company establishes task force to investigate solutions

## INVESTIGATION BEHIND PLUGGING



- Popcorn / large particle ash develops from ash deposits on the boiler tubes.
  - The deposits on the boiler tubes hardens and breaks off.
  - This hardened LPA is easily carried over into the SCR.
  - Other operating parameters
  - SCS investigates short and long-term solutions
- Task Force recommends catalyst “rejuvenation”





# LABORATORY TESTING

- Envirgy and Enerfab to perform laboratory tests on plugged Bowen catalyst
- Test locations: Vienna, Austria and Cincinnati, OH
- Patented “oscillation” process proved successful during the tests
- Process optimization using different solution additives
- Test results: >95% open channels





## TECHNOLOGICAL SOLUTION

- Based on the laboratory testing performed by the team of Envirgy and Enerfab, Southern Company decide to enter into an agreement for the rejuvenation of the Plant Bowen catalysts.
- Decision Factors: cost, schedule, on-site process
- Removal and reinstallation of the catalyst modules awarded to Enerfab
- “Total Scope” approach led to an efficient and flexible schedule which met Southern Company’s needs.
- Envirgy and Enerfab guarantees:
  - Catalyst restored to >90% open channels
  - No influence on physical or chemical properties of the catalyst
  - Removal, regeneration and reinstall per contract schedule

## CATALYST REJUVENATION PROCESS



## CATALYST REJUVENATION PROCESS





## CATALYST REJUVENATION PROCESS



## CATALYST REJUVENATION PROCESS




## CATALYST REJUVENATION PROCESS





## CATALYST REJUVENATION RESULTS




- Achieved > 95% open channels
- No influence on the physical properties of the catalyst
- No influence on the chemical properties of the catalyst
- Met contract schedule



## CATALYST REJUVENATION RESULTS

Relative Catalyst Activity Comparison



## CATALYST REJUVENATION CONCLUSIONS

### “On-site” Catalyst Rejuvenation Benefits:

- No negative impacts to the physical or chemical properties of the catalyst
  - Can extend the life span of a catalyst
  - Can be successfully performed within a specified time frame.
- 
- Rejuvenated catalyst performed successfully the entire 2003 Ozone Season.
  - Cost effective solution as an integral part of a Catalyst Management Program.